

Government of West Bengal
Office of the Deputy Director, West Bengal Fire & Emergency Services
North Bengal Region, Siliguri



Memo No. WBEES/1000/FF/ 188 /19

Date: 28/8/2019

From: The Deputy Director,
West Bengal Fire & Emergency Services
North Bengal Region, Siliguri.

To : The Secretary,
Bergapur Public School,
Belitanga, India, Uttar Bangga.

Sub: Functional N.C.C. for existing 2-1 story Educational Building of the Bergapur Public School, India, Uttar Bangga.

Dear Sir/Madam,

In reference to your application regarding provisional Fire Safety Certificate of the abovesaid school building, I am directed to state that the said premises has inspected and following Fire Safety measures have been estimated and recommended. For necessary compliance within 4 (four) weeks.

Recommendations

A. Water Services in an educational Building Code

No educational premises having water supply of 75,000 Litres and a sprinkling arrangement shall have to be provided with a **Hydrant Protection** at specific points.

B. Fire Pump

A Fire Pump shall have to be provided to obtain design pressure of maximum 7 (seven) along with a **Water Pump**.

C. Wet Rise Alarm and hose System I.S. 1000:1995

The building shall be provided with the provision of Wet Rise having landing Valves & Hose-reel-hose system at each floor level.

D. Detection & Alarm system I.S.1209

Manually operated fire alarm system with at least 5 nos. of break glass type call boxes fitted with buzzer at each floor connecting with audio visual panel board shall have to be provided at the entrance of ground floor level of the school building.

E. Fire and Firefighting System as per I.S.1209

Fire and Fire fighting arrangement shall be in the order of placing suitable type of portable Fire Extinguisher, Fire Buckets etc. in all floors and vulnerable locations of the building and shall be in accordance with the above specification.

The compliance of all the fire and life safety measures as recommended herein above as approved, have to be made to this office for necessary inspection and issuing of the certificate, and **FINAL SAFETY CERTIFICATE** will be issued in favor of the above premises only on satisfactory performance of all the safety measures.

Thanking You,


Deputy Director
West Bengal Fire & Emergency Services
North Bengal Region, Siliguri.